

The “Grid”: Influence of Existing Infrastructure on Energy Development and Siting

Workshop on Onshore Implications
March 25, 2010


Grid Influence on Offshore Energy Siting




Two aspects to grid influence on siting

- Transmission lines back to shore
- Effect of the power on the system
 - Amount of power ► grid robustness
 - Intermittency - not limited to dealing locally with this

Mean Annual Wind Power Density of South Carolina at 100 Meters







SC Roadmap to Coastal Clean Energy



3-part Mission:

- **Study Transmission Infrastructure and Develop Options for Integrating Offshore Wind**
- Study Wind, Wave and Current Energy for Wind Turbine Foundation Design and for Other Potential Marine Energy Development
- Regulatory Coordination Task Force to Develop Permitting Process

Partners:

SC Energy Office Coastal Carolina Univ
Clemson Univ Restoration Inst
Santee Cooper NC State Univ



Transmission Study - Scope



Three Future Scenarios

- Phase I - 80 MW in state waters by 2014
- Phase II - additional 1 GW in federal waters by 2020 (total 1,080 MW)
- Phase III - additional 2 GW in federal waters by 2030 (total 3,080 MW)

DOE says 1-5 GW of offshore wind generation for SC

Transmission Study - Assumptions



- Power enters at North and South points
- Six logical locations to access 115kV network
- Used GE 3.6MW wind turbine parameters
- 34.5 kV stepped up to 115kV at interconnect locations
- Looked for
 - Acceptable voltage range for this purpose is $94\% < V < 106\%$
 - Line and transformer loading must be $< 100\%$
- Wind energy is distributed to four electric utilities in SC (Duke, Progress, SCE&G and Santee Cooper) based on load ratio share
- Existing generation at the four utilities are reduced according to the same load ratio share

Transmission Study - Results



- The existing 115 kV network is sufficient for 80MW in 2014.
- The existing 115 kV network is sufficient for 1,080MW in 2020 under normal operating conditions.
- The existing 230kV network is also sufficient for 1,080 MW under normal operating conditions. This would in turn lower the flows on the 115kV network.

Transmission Study - Results



- The existing 230kV network is sufficient for up to 2.0 GW in the 2020 scenario under normal operating conditions.
- The 230kV network will require some new lines to handle the 3.08 GW scenario.

All results are stated with no contingency (n-1).

Transmission Study – Future Study




- Scenario III – 3080 MW and recommendations for redesign or upgrade
- Additional Studies on
 - Contingency and short circuit analysis
 - Dynamic stability
 - Voltage stability
 - Transient stability


Acknowledgments

- Dr. Adly Girgis and Dr. Elham Makram at Clemson Univ Electric Power Research (CUEPRA) and their student researchers
- Clemson's South Carolina Institute for Energy Studies
- Santee Cooper's Transmission Department
 - Tom Abrams
- SCE&G's Transmission Department
 - Clay Young
- South Carolina Regional Transmission Planning

Transmission Routing to Shore-based Interconnection




Transmission Routing to Shore-based Interconnection



Transmission Routing to Shore-based Interconnection



Transmission Routing to Shore-based Interconnection



Conclusions



- No project planned
- Lots of studies to be done
- Four entities in South Carolina have applied for MMS studies related to offshore wind investigations
 - RPI team – Marine Spatial Planning Database – Topic 8
 - CCU and Rutgers – Physical Oceanography - Topic 3
 - OCC/AWS Truewind – Visual Evaluations – Topic 6
 - CCU – Environmental Monitoring Technologies -Topic 4
- Continue our work along with other researchers in SC